



## PVC Insulation Jumper Wire (JW)



# Construction

1. Conductor

Tinned annealed copper, solic

2. Insulation

: Polyvinyi chionae

0.5 mm gauge

Black and Yellow

65 mm gauge : Red and White

or others upon reques

#### Reference Standard

TOT Spec. No.: OES - 003 - 093 - 09

### Marking

No markina

### Application

This wire is designed for making cross connection on distribution frames and in terminals in the telephone exchanges or in the cross connecting cabinet.

Conductor	Number	Thickness	Insulated	Overall	Cable	Standard
diameter	of	of	core	diameter	weight	length
	cores	insulation	diameter			
mm	С	mm	mm	mm	kg/km	(m/coil)
(Nominal)		(Nominal)	(Approx.)	(Approx.)	(Approx.)	
0.5		0.0	1.10	0.0	F /	000
(24 AWG)	2	0.3	1.10	2.2	5.6	200
0.65						
(22 AWG)	2	0.3	1.25	2.5	8.4	200

Note:

1. BCC Specification No. : TEA 010/0208

Revision: 01, August 2012 www.bangkokcable.com C 15